

SUITABLE FOR MODEL**⚠ WARNING**

To avoid the risk of fire, or electric shock this product should be installed, inspected, and maintained by a qualified electrician only. Installation should be completely by an individual familiar with the construction and operation of the luminaire. Installation of luminaire must be in accordance with nation and local building and electrical codes.

Safety Warning:

To avoid electric shock:

Be certain electrical power is OFF before and during installation and maintenance.

Luminaire must be supplied by a wiring system with an equipment grounding conductor.

To avoid burning hands:

Make sure lens and housing are cool when performing maintenance.

To avoid product degradation:

Make sure the wire supply voltage is the same as the luminaire supply

Use proper supply wiring as specified on the luminaire nameplate.

Avoid use in environments containing sulfur, chlorine, or other halides, methyl acetate or ethyl acetate, cyanoacrylates, glycol ethers, formaldehyde or butadiene.

Notes:

Instructions do not cover all details and all possible product configurations.

Do not restrict luminaire ventilation.

Ensure LED luminaire is not covered with material that will prevent convection or conduction cooling.

Ensure LED luminaire has the correct polarity before installation

Avoid exposing wiring to metal edges and sharp objects.

Maintenance:

Perform visual, electrical, and mechanical inspections on a regular basis. The environment and frequency of use should determine this. However, it is recommended that checks be made at least once a year. Electrically check to make sure that all connections are clean and tight. Mechanically check that all parts are properly assembled.

WIRE CONNECTION

Universal Voltage permits operation at 120VAC thru 347VAC, 50 or 60 Hz.

- a. Connect the black luminaire lead to the supply lead.
- b. Connect the white luminaire lead to the neutral supply lead.
- c. Connect the green or green/yellow ground lead to the green supply lead.
- d. If Dimming is an option; connect the violet dimming positive lead to the supply dimming positive lead. If dimming is not being used, ensure to cap off the violet lead.
- e. If Dimming is an option; connect the pink dimming negative lead to the supply dimming negative lead. If dimming is not being used, ensure to cap off the pink lead.

Fixture without Sensor

	LUMINAIRE
LINE	BLACK
GROUND	GREEN
NEUTRAL	WHITE
DIM (+)	VIOLET
DIM (-)	PINK

Fixture with Sensor

	LUMINAIRE
LINE	BLACK
GROUND	GREEN
NEUTRAL	WHITE

INSTALLATION

Mounting Steps

1. Locate the mounting points based on the Dimension Drawing.
2. Secure the mounting plate on the wall with Screw A (2)
3. Use the mounting plate to hook the fixture and secure it by Screw B (2).

